

TYPE-EXAMINATION CERTIFICATE

FIRE RESISTANCE OF LIFT LANDING DOORS

Issued by Liftinstituut B.V.

- Certificate nr. : NL 07-400-1002-061-02 Revision nr. -
- Description of the product : Fire resistant side opening telescopic lift landing door
- Trademark, type : Merih, OKATT2P0100040
- Name and address of the manufacturer : Merih Asansor Sanayi ve Ticaret A.S.
Ivedik Organize Sanayi Bolgesi 691.Sokak No:72
Ostim - Ankara, Turkey
- Name and address of the certificate holder : Merih Asansor Sanayi ve Ticaret A.S.
Ivedik Organize Sanayi Bolgesi 691.Sokak No:72
Ostim - Ankara, Turkey
- Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC; EN 81-58:2003
- Test laboratory : Efectis Nederland B.V.
- Date and number of the laboratory report : 2007, 2007-Efectis-R0118
- Date of type-examination : February 4, 2007
- Classification
- | | | | |
|---|----|----|----|
| The performance criteria of the EN 81-58 covered are: | | | |
| | E | EI | EW |
| Merih, OKATT2P0100040, telescopic side opening | 90 | 45 | 60 |
- Annexes with this certificate : Report belonging to the type-examination certificate; NL 07-400-1002-061-02
- Additional remarks : -
- Conclusion : The landing door OKATT2P0100040 meets the requirements of the Lift Directive, Annex I section 4.2 and the EN 81-58:2003, in particular for the classification indicated above.



Issued in Amsterdam
Date of issue : February 15, 2007

Liftinstituut Holding B.V.
managing director