

EC TYPE-EXAMINATION CERTIFICATE

Acting under the Warenwetbesluit liften issued by Liftinstituut B.V.
identification number Notified Body 0400,
commissioned by Besluit no. A&G/W&P/03 56126 of October 15th, 2003

Certificate nr. : NL 09-400-1002-061-03 Revision nr.: -

Description of the product : Door locking device with hook for horizontal power operated sliding doors. Both central and side opening

Trademark, type : Merih Asansör, KLT 002

Name and address of the manufacturer : Merih Asansör San. Ve TIC. PAZ. LTD. ŞTI.
Ivedik Organize San Bölğ. Ari San Sit. 691 sk. No.68-70-72
Ostim, Ankara Turkye

Name and address of the certificate holder : Merih Asansör San. Ve TIC. PAZ. LTD. ŞTI.
Ivedik Organize San Bölğ. Ari San Sit. 691 sk. No.68-70-72
Ostim, Ankara Turkye

Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC
EN 81-1, EN 81-2

Test laboratory : None

Date and number of the laboratory report : None

Date of EC type-examination: September 2008 - January 2009

Annexes with this certificate : Report belonging to the EC type-examination certificate
nr.: NL 09-400-1002-061-03

Additional remarks : Max. rated voltage 230 VAC
Max. rated current 0,5A
Max. door height 2100 mm
Door width 700 - 1300 mm
Max. panel mass 50 kg

Conclusion : The safety component meets the requirements of the Lifts Directive 95/16/EC taking into account any additional remarks mentioned above



Issued in Amsterdam
Date of issue : January 13, 2009

Liftinstituut B.V.
Senior Officer Certification &
Technology

EC TYPE-EXAMINATION CERTIFICATE

Acting under the Warenwetbesluit liften issued by Liftinstituut B.V.
Identification number Notified Body 0400,
commissioned by Besluit no. A&G/W&P/03 56126 of October 15th, 2003

Certificate nr. : NL 09-400-1002-061-04 Revision nr.: 1.0

Description of the product : Door locking device with hook for horizontal power operated sliding doors. Both central and side opening

Trademark, type : Merih Asansör, KLT 003

Name and address of the manufacturer : Merih Asansör Sanayi ve Ticaret A.Ş.
Ivedik Organize San Bölğ. Ari San Sit. 691 sk. No.68-70-72
Ostim, Ankara Turkye

Name and address of the certificate holder : Merih Asansör Sanayi ve Ticaret A.Ş.
Ivedik Organize San Bölğ. Ari San Sit. 691 sk. No.68-70-72
Ostim, Ankara Turkye

Certificate issued on the basis of the following requirements : Lifts Directive 95/16/EC
EN 81-1, EN 81-2

Test laboratory : Liftinstituut, Merih Asansör

Date and number of the laboratory report : None

Date of EC type-examination: March 2009

Annexes with this certificate : Report belonging to the EC type-examination certificate
nr.: NL 09-400-1002-061-04

Additional remarks : Max. rated voltage 230 VAC
Max. rated current 0,5A
Max. door height 2100 mm
Door width 700 - 1300 mm
Max. panel mass 50 kg

Conclusion : The safety component meets the requirements of the Lifts
Directive 95/16/EC taking into account any additional remarks
mentioned above



Issued in Amsterdam
Date of issue : April 27, 2009

Liftinstituut B.V.
Senior Officer Certification &
Technology